

C.O.C.: DW42054

REPORT No. B12-21240

Report To:

Property Management Inc
 48 King Street,
 Trenton Ont K8V 3V8 Canada

Attention: Isaac Berman

Caduceon Environmental Laboratories

285 Dalton Ave
 Kingston Ontario K7K 6Z1
 Tel: 613-544-2001
 Fax: 613-544-2770

DATE RECEIVED: 21-Aug-12

DATE REPORTED: 27-Aug-12

SAMPLE MATRIX: Drinking Water

JOB/PROJECT NO.: HMR Estates Pump House

P.O. NUMBER:

WATERWORKS NO. 260027768

| Parameter | Total Coliform | E coli | Heterotrophic Plate Count | | |
|--------------------|----------------|-------------|---------------------------|--|--|
| Units | cfu/100mL | cfu/100mL | cfu/mL | | |
| M.D.L. | 1 | 1 | 10 | | |
| Reference Method | MOE E3407 | MOE E3407 | SM9215D | | |
| Date Analyzed/Site | 22-Aug-12/K | 22-Aug-12/K | 22-Aug-12/K | | |

| Client I.D. | Sample I.D. | Date Collected | Total Coliform | E coli | Heterotrophic Plate Count | | |
|----------------|-------------|----------------|----------------|--------|---------------------------|--|--|
| 19A Buffalo Dr | B12-21240-1 | 21-Aug-12 | 0 | 0 | 30 | | |
| Pumphouse-Raw | B12-21240-2 | 21-Aug-12 | 0 | 0 | | | |



Richard Lecompte
 Supervisor/Microbiology

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.