

C.O.C.: DW47383

REPORT No. B12-29315

**Report To:**

**Property Management Inc**  
 48 King Street,  
 Trenton Ont K8V 3V8 Canada

**Attention:** Isaac Berman

**Caduceon Environmental Laboratories**

285 Dalton Ave  
 Kingston Ontario K7K 6Z1  
 Tel: 613-544-2001  
 Fax: 613-544-2770

DATE RECEIVED: 19-Nov-12

JOB/PROJECT NO.: 104 Ellisville Rd - Pumphouse

DATE REPORTED: 21-Nov-12

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 260019591

<b>Parameter</b>	Total Coliform	E coli			
<b>Units</b>	cfu/100mL	cfu/100mL			
<b>M.D.L.</b>	1	1			
<b>Reference Method</b>	MOE E3407	MOE E3407			
<b>Date Analyzed/Site</b>	20-Nov-12/K	20-Nov-12/K			

<b>Client I.D.</b>	<b>Sample I.D.</b>	<b>Date Collected</b>				
Trailer #24	B12-29315-1	19-Nov-12	0	0		



Richard Lecompte  
 Supervisor/Microbiology

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.