

C.O.C.: DW38593

REPORT No. B12-29030

Report To:

Property Management Inc
 48 King Street,
 Trenton Ont K8V 3V8 Canada

Attention: Isaac Berman

Caduceon Environmental Laboratories

285 Dalton Ave
 Kingston Ontario K7K 6Z1
 Tel: 613-544-2001
 Fax: 613-544-2770

DATE RECEIVED: 14-Nov-12

JOB/PROJECT NO.: Lyn Valley Mobile Home

DATE REPORTED: 20-Nov-12

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 260023465

Client I.D.	70 Main St W	Pumphouse	70 Main St W	Pumphouse
Sample I.D.	B12-29030-1	B12-29030-2	B12-29030-3	B12-29030-4
Date Collected	14-Nov-12	14-Nov-12	14-Nov-12	14-Nov-12

Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed				
Total Coliform	cfu/100mL	1	MOE E3407	15-Nov-12/K	0			0
E coli	cfu/100mL	1	MOE E3407	15-Nov-12/K	0			0
Heterotrophic Plate Count	cfu/mL	10	SM9215D	15-Nov-12/K	< 10			
Nitrite (N)	mg/L	0.1	SM4110C	16-Nov-12/O		< 0.1		
Nitrate (N)	mg/L	0.1	SM4110C	16-Nov-12/O		< 0.1		
Nitrate + Nitrite (N)	mg/L	0.1	SM4110C	16-Nov-12/O		< 0.1		
Chloroform	µg/L	0.3	EPA 8260	16-Nov-12/O			0.6	
Bromodichloromethane	µg/L	0.1	EPA 8260	16-Nov-12/O			1.4	
Dibromochloromethane	µg/L	0.1	EPA 8260	16-Nov-12/O			2.8	
Bromoform	µg/L	0.1	EPA 8260	16-Nov-12/O			1.6	
Total Trihalomethanes	µg/L	0.3	EPA 8260	16-Nov-12/O			6.4	



Michelle Dubien
 Lab Supervisor

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.