

C.O.C.: DW47847

REPORT No. B12-32343

Report To:

Property Management Inc

48 King Street,
 Trenton Ont K8V 3V8 Canada

Attention: Isaac Berman

Caduceon Environmental Laboratories

285 Dalton Ave
 Kingston Ontario K7K 6Z1

Tel: 613-544-2001

Fax: 613-544-2770

DATE RECEIVED: 27-Dec-12

JOB/PROJECT NO.: HMR Estates Pump House

DATE REPORTED: 31-Dec-12

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 260027768

Client I.D.	19A Buffalo Dr.		
Sample I.D.	B12-32343-1		
Date Collected	27-Dec-12		

Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed			
Total Coliform	cfu/100mL	1	MOE E3407	28-Dec-12/K	0		
E coli	cfu/100mL	1	MOE E3407	28-Dec-12/K	0		
Heterotrophic Plate Count	cfu/mL	10	SM9215D	28-Dec-12/K	< 10		



Michelle Dubien
 Lab Supervisor

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.