

C.O.C.: DW50239

REPORT No. B13-06762

**Report To:**

**Property Management Inc**  
 48 King Street,  
 Trenton Ont K8V 3V8 Canada

**Attention:** Isaac Berman

**Caduceon Environmental Laboratories**

285 Dalton Ave  
 Kingston Ontario K7K 6Z1  
 Tel: 613-544-2001  
 Fax: 613-544-2770

DATE RECEIVED: 27-Mar-13

JOB/PROJECT NO.: Lyn Valley Mobile Home

DATE REPORTED: 01-Apr-13

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 260023465

Parameter	Total Coliform	E coli	Heterotrophic Plate Count		
Units	cfu/100mL	cfu/100mL	cfu/mL		
M.D.L.	1	1	10		
Reference Method	MOE E3407	MOE E3407	SM9215D		
Date Analyzed/Site	27-Mar-13/K	27-Mar-13/K	27-Mar-13/K		

Client I.D.	Sample I.D.	Date Collected				
70 Main St-W	B13-06762-1	27-Mar-13	0	0	< 10	
Pumphouse-Raw	B13-06762-2	27-Mar-13	0	0		



Natasha Popkie

for Richard Lecompte Lab Supervisor

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.