

C.O.C.: G41102

REPORT No. B14-20014

**Report To:**

**Property Management Inc**  
 48 King Street,  
 Trenton Ont K8V 3V8 Canada

**Attention:** Isaac Berman

**Caduceon Environmental Laboratories**

285 Dalton Ave  
 Kingston Ontario K7K 6Z1  
 Tel: 613-544-2001  
 Fax: 613-544-2770

DATE RECEIVED: 11-Aug-14

JOB/PROJECT NO.:

DATE REPORTED: 22-Aug-14

P.O. NUMBER:

SAMPLE MATRIX: Waste Water

WATERWORKS NO.

<b>Client I.D.</b>	Lyn Valley-Effluent	Lyn Valley-Raw		
<b>Sample I.D.</b>	B14-20014-1	B14-20014-2		
<b>Date Collected</b>	11-Aug-14	11-Aug-14		

Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed				
E coli	cfu/100mL	1	SM9222B	11-Aug-14/K	13000	232000		
pH @25°C	pH Units		SM4500H+	11-Aug-14/K	7.64	7.15		
CBOD5	mg/L	2	SM 5210B	13-Aug-14/K	10	204		
Total Suspended Solids	mg/L	3	SM2540D	12-Aug-14/K	22	75		
Phosphorus-Total	mg/L	0.01	E3199A.1	12-Aug-14/K	2.21	8.68		
Total Kjeldahl Nitrogen	mg/L	0.1	E3199A.1	12-Aug-14/K	8.8	70.6		
Ammonia (N)-Total	mg/L	0.01	SM4500-NH3-H	15-Aug-14/K	6.48	5.99		
Ammonia (N)-unionized	mg/L	0.01	CALC	15-Aug-14/K	0.12	0.04		
Nitrite (N)	mg/L	0.1	SM4110C	12-Aug-14/O	4.5	< 0.1		
Nitrate (N)	mg/L	0.1	SM4110C	12-Aug-14/O	3.2	< 0.1		



Richard Lecompte  
 Lab Supervisor

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.