

C.O.C.: G44587

REPORT No. B15-19662

**Report To:**

**Property Management Inc**  
 323 Dundas Street East, Unit 3,  
 Trenton Ont K8V 5W5 Canada

**Attention:** Isaac Berman

**Caduceon Environmental Laboratories**

285 Dalton Ave  
 Kingston Ontario K7K 6Z1  
 Tel: 613-544-2001  
 Fax: 613-544-2770

DATE RECEIVED: 04-Aug-15

JOB/PROJECT NO.: Lyn Valley Mobile Park

DATE REPORTED: 13-Aug-15

P.O. NUMBER:

SAMPLE MATRIX: Waste Water

WATERWORKS NO.

<b>Client I.D.</b>	Lyn Valley-Effluent	Lyn Valley-Raw		
<b>Sample I.D.</b>	B15-19662-1	B15-19662-2		
<b>Date Collected</b>	04-Aug-15	04-Aug-15		

Parameter	Units	R.L.	Reference Method	Date/Site Analyzed				
E coli	cfu/100mL	1	SM9222B	05-Aug-15/K	9800	32000		
CBOD5	mg/L	2	SM 5210B	05-Aug-15/K	2	144		
Total Suspended Solids	mg/L	3	SM2540D	07-Aug-15/K	10	60		
Phosphorus-Total	mg/L	0.01	E3199A.1	06-Aug-15/K	1.69	8.16		
Total Kjeldahl Nitrogen	mg/L	0.1	E3199A.1	06-Aug-15/K	6.4	76.1		
Ammonia (N)-Total	mg/L	0.01	SM4500-NH3-H	10-Aug-15/K	5.07	65.4		
Ammonia (N)-unionized	mg/L	0.01	CALC	10-Aug-15/K	< 0.01	0.35		
Nitrite (N)	mg/L	0.1	SM4110C	05-Aug-15/O	0.4	< 0.1		
Nitrate (N)	mg/L	0.1	SM4110C	05-Aug-15/O	0.4	< 0.1		



Michelle Dubien  
 Lab Manager

R.L. = Reporting Limit  
 Site Analyzed: K-Kingston, W-Windsor, O-Ottawa, R-Richmond Hill  
 Uncertainty Values available upon request

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.