

C.O.C.: DW61838

REPORT No. B15-30691

**Report To:**

**Property Management Inc**  
 323 Dundas Street East, Unit 3,  
 Trenton Ont K8V 5W5 Canada

**Attention:** Isaac Berman

**Caduceon Environmental Laboratories**

285 Dalton Ave  
 Kingston Ontario K7K 6Z1  
 Tel: 613-544-2001  
 Fax: 613-544-2770

DATE RECEIVED: 24-Nov-15

JOB/PROJECT NO.: HMR Estates Pump House

DATE REPORTED: 26-Nov-15

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 260027768

<b>Parameter</b>	Total Coliform	E coli	Heterotrophic Plate Count		
<b>Units</b>	cfu/100mL	cfu/100mL	cfu/mL		
<b>R.L.</b>	1	1	10		
<b>Reference Method</b>	MOE E3407	MOE E3407	SM9215D		
<b>Date Analyzed/Site</b>	24-Nov-15/K	24-Nov-15/K	24-Nov-15/K		

<b>Client I.D.</b>	<b>Sample I.D.</b>	<b>Date Collected</b>				
19A Buffalo Dr.	B15-30691-1	24-Nov-15	0	0	10	



Derek Winterton  
 for Richard Lecompte Lab Supervisor

R.L. = Reporting Limit

Site Analyzed: K-Kingston, W-Windsor, O-Ottawa, R-Richmond Hill

Uncertainty Values available upon request

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.