

C.O.C.: DW62195

REPORT No. B16-00804

Report To:

Property Management Inc
323 Dundas Street East, Unit 3,
Trenton Ont K8V 5W5 Canada

Attention: Isaac Berman

Caduceon Environmental Laboratories

285 Dalton Ave
Kingston Ontario K7K 6Z1
Tel: 613-544-2001
Fax: 613-544-2770

DATE RECEIVED: 12-Jan-16

JOB/PROJECT NO.: HMR Estates Pump House

DATE REPORTED: 13-Jan-16

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 260027768


Parameter			Total Coliform	E coli			
Units			cfu/100mL	cfu/100mL			
R.L.			1	1			
Reference Method			MOE E3407	MOE E3407			
Date Analyzed/Site			12-Jan-16/K	12-Jan-16/K			
Client I.D.	Sample I.D.	Date Collected					
Pumphouse	B16-00804-1	12-Jan-16	0	0			

R.L. = Reporting Limit

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.


Derek Winterton
for Richard Lecompte Lab Supervisor