

C.O.C.: DW61199

REPORT No. B16-10492

Report To:

Property Management Inc
 323 Dundas Street East, Unit 3,
 Trenton Ont K8V 5W5 Canada

Attention: Isaac Berman

Caduceon Environmental Laboratories

285 Dalton Ave
 Kingston Ontario K7K 6Z1
 Tel: 613-544-2001
 Fax: 613-544-2770

DATE RECEIVED: 26-Apr-16

JOB/PROJECT NO.: HMR Estates Pump House

DATE REPORTED: 29-Apr-16

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 260027768

Parameter	Total Coliform	E coli	Heterotrophic Plate Count		
Units	cfu/100mL	cfu/100mL	cfu/mL		
R.L.	1	1	10		
Reference Method	MOE E3407	MOE E3407	SM9215D		
Date Analyzed/Site	26-Apr-16/K	26-Apr-16/K	26-Apr-16/K		

Client I.D.	Sample I.D.	Date Collected				
19A Buffalo Dr	B16-10492-1	26-Apr-16	0	0	< 10	



Natasha Popkie
 for Richard Lecompte Lab Supervisor

R.L. = Reporting Limit
 Test methods may be modified from specified reference method unless indicated by an *
 Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.