

**C.O.C.: DW76615**

**REPORT No. B17-11600**

**Report To:**

**Property Management Inc**  
323 Dundas Street East, Unit 3,  
Trenton Ont K8V 5W5 Canada

**Attention:** Isaac Berman

**Caduceon Environmental Laboratories**

285 Dalton Ave  
Kingston Ontario K7K 6Z1  
Tel: 613-544-2001  
Fax: 613-544-2770

DATE RECEIVED: 03-May-17

JOB/PROJECT NO.: Lyn Valley Mobile Home

DATE REPORTED: 08-May-17

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 260023465

			<b>Client I.D.</b>	70 Main St. W			
			<b>Sample I.D.</b>	B17-11600-1			
			<b>Date Collected</b>	03-May-17			
Parameter	Units	R.L.	Reference Method	Date/Site Analyzed			
Chloroform	µg/L	0.3	EPA 8260	05-May-17/O	1.1		
Bromodichloromethane	µg/L	0.1	EPA 8260	05-May-17/O	3.2		
Dibromochloromethane	µg/L	0.1	EPA 8260	05-May-17/O	7.5		
Bromoform	µg/L	0.1	EPA 8260	05-May-17/O	4.1		
Total Trihalomethanes	µg/L	0.3	EPA 8260	05-May-17/O	16.0		



R.L. = Reporting Limit

Test methods may be modified from specified reference method unless indicated by an \*

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

Richard Lecompte  
Lab Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.