

C.O.C.: DW85707

REPORT No. B18-09059

Report To:

Property Management Inc
 323 Dundas Street East, Unit 3,
 Trenton Ont K8V 5W5 Canada

Attention: Isaac Berman

Caduceon Environmental Laboratories

285 Dalton Ave
 Kingston Ontario K7K 6Z1
 Tel: 613-544-2001
 Fax: 613-544-2770

DATE RECEIVED: 10-Apr-18

JOB/PROJECT NO.: Lyn Valley Mobile Home

DATE REPORTED: 12-Apr-18

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 260023465

Parameter			Total Coliform	E coli	Heterotrophic Plate Count		
Units			cfu/100mL	cfu/100mL	cfu/mL		
R.L.			1	1	10		
Reference Method			MOE E3407	MOE E3407	SM9215D		
Date Analyzed/Site			10-Apr-18/K	10-Apr-18/K	10-Apr-18/K		
Client I.D.	Sample I.D.	Date Collected					
70 Main St W	B18-09059-1	10-Apr-18	0	0	< 10		
Pumphouse-Raw	B18-09059-2	10-Apr-18	0	0			

E. Livermore

R.L. = Reporting Limit

Test methods may be modified from specified reference method unless indicated by an *

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill,B-Barrie

Evan Livermore
 for Richard Lecompte Lab Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.