

C.O.C.: DW099553

REPORT No. B18-38690

Report To:

Property Management Inc
323 Dundas Street East, Unit 3,
Trenton Ont K8V 5W5 Canada

Attention: Isaac Berman

Caduceon Environmental Laboratories

285 Dalton Ave
Kingston Ontario K7K 6Z1
Tel: 613-544-2001
Fax: 613-544-2770

DATE RECEIVED: 19-Dec-18

JOB/PROJECT NO.: 227 Big Hill Rd - Pumphouse

DATE REPORTED: 21-Dec-18

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 260019604

Parameter	Total Coliform	E coli	Heterotrophic Plate Count		
Units	cfu/100mL	cfu/100mL	cfu/mL		
R.L.	1	1	10		
Reference Method	MOE E3407	MOE E3407	SM9215D		
Date Analyzed/Site	19-Dec-18/K	19-Dec-18/K	19-Dec-18/K		
Client I.D.	Sample I.D.	Date Collected			
#24	B18-38690-1	19-Dec-18	0	0	< 10

E. Livermore

R.L. = Reporting Limit

Test methods are modified from specified reference method unless indicated by an *

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill,B-Barrie

Evan Livermore
for Richard Lecompte Lab Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.