

C.O.C.: DW099556

REPORT No. B19-00349

Report To:

Property Management Inc
 323 Dundas Street East, Unit 3,
 Trenton Ont K8V 5W5 Canada

Attention: Isaac Berman

Caduceon Environmental Laboratories

285 Dalton Ave
 Kingston Ontario K7K 6Z1
 Tel: 613-544-2001
 Fax: 613-544-2770

DATE RECEIVED: 03-Jan-19

JOB/PROJECT NO.: HMR Estates Pump House

DATE REPORTED: 07-Jan-19

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 260027768

Parameter	Total Coliform	E coli	Heterotrophic Plate Count		
Units	cfu/100mL	cfu/100mL	cfu/mL		
R.L.	1	1	10		
Reference Method	MOE E3407	MOE E3407	SM9215D		
Date Analyzed/Site	03-Jan-19/K	03-Jan-19/K	03-Jan-19/K		

Client I.D.	Sample I.D.	Date Collected	Total Coliform	E coli	Heterotrophic Plate Count		
19A Buffalo Dr	B19-00349-1	03-Jan-19	0	0	< 10		
Pumphouse-Raw	B19-00349-2	03-Jan-19	0	0			



R.L. = Reporting Limit

Test methods are modified from specified reference method unless indicated by an *

Site Analyzed=K-Kingston, W-Windsor, O-Ottawa, R-Richmond Hill, B-Barrie

Evan Livermore
 for Richard Lecompte Lab Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.