

**C.O.C.: DW099569**

**REPORT No. B19-02848**

**Report To:**

**Property Management Inc**  
323 Dundas Street East, Unit 3,  
Trenton Ont K8V 5W5 Canada

**Attention:** Isaac Berman

**Caduceon Environmental Laboratories**

285 Dalton Ave  
Kingston Ontario K7K 6Z1  
Tel: 613-544-2001  
Fax: 613-544-2770

DATE RECEIVED: 30-Jan-19

JOB/PROJECT NO.: Lyn Valley Mobile Home

DATE REPORTED: 01-Feb-19

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 260023465

Parameter	Total Coliform	E coli	Heterotrophic Plate Count		
Units	cfu/100mL	cfu/100mL	cfu/mL		
R.L.	1	1	10		
Reference Method	MOE E3407	MOE E3407	SM9215D		
Date Analyzed/Site	30-Jan-19/K	30-Jan-19/K	30-Jan-19/K		
Client I.D.	Sample I.D.	Date Collected			
70 Main St W	B19-02848-1	30-Jan-19	0	0	110

*E. Livermore*

R.L. = Reporting Limit

Test methods are modified from specified reference method unless indicated by an \*

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill,B-Barrie

Evan Livermore  
Senior Microbiology Analyst

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.