

C.O.C.: DW099737

REPORT No. B20-05088

**Report To:**

**Property Management Inc**  
 323 Dundas Street East, Unit 3,  
 Trenton Ont K8V 5W5 Canada

**Attention:** Isaac Berman

**Caduceon Environmental Laboratories**

285 Dalton Ave  
 Kingston Ontario K7K 6Z1  
 Tel: 613-544-2001  
 Fax: 613-544-2770

DATE RECEIVED: 24-Feb-20

JOB/PROJECT NO.: 227 Big Hill Rd - Pumphouse

DATE REPORTED: 26-Feb-20

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 260019604

<b>Parameter</b>	Total Coliform	E coli	Heterotrophic Plate Count		
<b>Units</b>	cfu/100mL	cfu/100mL	cfu/mL		
<b>R.L.</b>	1	1	10		
<b>Reference Method</b>	MOE E3407	MOE E3407	SM9215D		
<b>Date Analyzed/Site</b>	24-Feb-20/K	24-Feb-20/K	24-Feb-20/K		

<b>Client I.D.</b>	<b>Sample I.D.</b>	<b>Date Collected</b>				
#24	B20-05088-1	24-Feb-20	0	0	40	



R.L. = Reporting Limit

Test methods may be modified from specified reference method unless indicated by an \*

Site Analyzed=K-Kingston, W-Windsor, O-Ottawa, R-Richmond Hill, B-Barrie

Evan Livermore  
 Senior Microbiology Analyst

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.