

C.O.C.: DW098185

REPORT No. B20-09043

Report To:

Property Management Inc
 323 Dundas Street East, Unit 3,
 Trenton Ont K8V 5W5 Canada

Attention: Isaac Berman

DATE RECEIVED: 07-Apr-20

DATE REPORTED: 09-Apr-20

SAMPLE MATRIX: Drinking Water

Caduceon Environmental Laboratories

285 Dalton Ave
 Kingston Ontario K7K 6Z1
 Tel: 613-544-2001
 Fax: 613-544-2770

JOB/PROJECT NO.: Lyn Valley Mobile Home

P.O. NUMBER:

WATERWORKS NO. 260023465

Parameter	Total Coliform	E coli	Heterotrophic Plate Count		
Units	cfu/100mL	cfu/100mL	cfu/mL		
R.L.	1	1	10		
Reference Method	MOE E3407	MOE E3407	SM9215D		
Date Analyzed/Site	07-Apr-20/K	07-Apr-20/K	07-Apr-20/K		

Client I.D.	Sample I.D.	Date Collected	Total Coliform	E coli	Heterotrophic Plate Count		
70 Main St W	B20-09043-1	07-Apr-20	0	0	430		
Pumphouse-Raw	B20-09043-2	07-Apr-20	0	0			



R.L. = Reporting Limit

Test methods may be modified from specified reference method unless indicated by an *

Site Analyzed=K-Kingston, W-Windsor, O-Ottawa, R-Richmond Hill, B-Barrie

Evan Livermore
 Senior Microbiology Analyst

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.